

Slip Check to AS 4586:2013

Alum Ceramic Non Skid Peel & Stick

NATA Accreditation Number 17139

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards

Accredited for compliance with ISO/IEC 17025

NATA is a signatory to the APLAC mutual recognition arrangement for the mutual recognition of the equivalence of testing, calibration and inspection reports

15 July 2014

Test Report No. R7003a

Slip Resistance Classification of New Pedestrian Surface Materials

AS 4586:2013 Appendix A (Wet Pendulum Test)

The slip resistance Classification has been determined for unused surfaces using specific conditions. Factors such as usage, cleaning systems, applied coatings and patterns of wear may affect the characteristics of the surface.

Requested by: Global Safe Technologies (Aust) Pty Ltd
Client Address: 26 Hassall Street

Smithfield NSW 2164
Product Manufacturer: Silva Non Skid Solutions
Product Description: Alum Ceramic Non Skid Peel & Stick

Test conducted according to: AS 4586:2013 Appendix A
Location: Slip Check Pty Ltd Test Facilities, Blacktown NSW 2148
Conducted by: Martin Daniel

Date: 28 May 2014 Temperature: 17°C
Sample: Unfixed Cleaning: None
Rubber slider used: Slider 96 Conditioned: Grade P 400 paper dry followed
Slope of specimen: Tested on a flat level surface by wet lapping film
Direction of Test: NA Wetting agent: Water

	Specimen 1	Specimen 2	Specimen 3	Specimen 4	Specimen 5
Mean BPN of last 3 swings:	73	71	71	69	71

Reported SRV of Sample:	71
Class:	P5



Ryan Voorderhake
Laboratory/Field Technician